Well Construction Report
WISCONSIN UNIQUE WELL NUMBER UX914

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LUTYNSKI, JARVIS	Phone #: (414)881-3414
Mailing Address: 122 W MAPLE ST	
City: GRAFTON	State: WI / Zip Code: 53024
County: Washington	Co. Permit #:
Notification #: 36859114	Completed: 06-25-2010
Well Constructor (Business Name): LAABS WELL DRILLING INC	Lic. #: 560
Facility ID # (Public Wells):	
Address: 445 NORTH RIVERVIEW DR, GRAFTON WI 53024-9757	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.3	

1. Well Location

Fire # (if avail.):

Town of JACKSON

Street Address or Road Name and Number: 580 WESTERN AVE

Subdivision Name: | Lot #: | Block #:

Latitude / Longitude in Decimal Degree (DD): 43.29368 °N -87.98683 °W

Method Code: GPS008

SE SE or Govt Lot # | Section: 25 | Township: 10 N | Range: 20 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of TREES

Private, non-potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	42
6	42	120

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — No
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
- Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				8. Geology Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	G	-	GRAVEL	Surface	28
-	-	L	-	LIMESTONE	28	120

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	18.97# PER FT WELDED JT N BLK STL A-53 PE WHEATLAND USA	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

8 ft. below ground surface

10. Pump Test

Pumping level 60 ft. below surface

Pumping at 15 GP for 1 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method BRAIDEN HEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	42	11 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RL		06-30-2010
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
DL		06-30-2010

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment: NO BLDG OVERHANG OR SEPTIC/SEWER

Water Quality Text:

Water Quantity Text:

Difficulty Text:

Created On: 07-21-2010 Created by: WELL CONST LOAD Updated On: 07-27-2010 Updated by: LYONSD